
# 2020 Annual Drinking Water Consumer Confidence Report (CCR) City of Denmark (0510002)



#### Spanish (Española)

Este informe contiene informacion muy importante sobre la calidad de su agua beber. Traduscalo o hable con alguien que lo entienda bien.

#### Is my water safe?

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about from where your water comes, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. If you have any questions about this report or concerning your water, please contact City Hall at (803) 793-3734. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled city council meetings held on the third Monday of each month. These meetings are typically held at city hall located at 64 City Hall Street, and begin at 5:00 PM. The public is encouraged to attend and participate.

# Do I need to take precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

#### Where does my water come from?

Our water comes from three groundwater well drilled into an underground source of water.

## Source water assessment and its availability.

Raw water sources are most susceptible to contamination from runoff or environmental conditions.

#### Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPAs) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. To ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

#### **Water Conservation Tips**

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature. Visit <a href="https://www.epa.gov/watersense">www.epa.gov/watersense</a> for more information.

- Take short showers.
- Shut off water while brushing your teeth.
- Use a water-efficient showerhead.
- · Run clothes washer and dishwasher only when full.

- · Water plants only when necessary.
- · Fix leaky toilets and faucets.
- · Adjust sprinklers so only your lawn is watered.
- · Teach your kids about water conservation.

#### **Source Water Protection Tips**

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides.
- Pick up after your pets.
- If you use a septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public system.
- Dispose of chemicals properly.
- Volunteer in your community. Find a watershed organization and volunteer to help. Use EPA's Adopt Your Watershed to locate groups in your community.
- Organize a storm drain stenciling project with your local government or water provider.

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CITY OF DENMARK (0510002) is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

#### Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

# WATER QUALITY DATA TABLE Monitoring Period of January 1 - December 31, 2020

Lead and Copper - Inorganic Contaminants

| Contaminants (unit of measure)             | MCLG or<br>MRDLG | AL  | Your<br>Water | # Samples<br>Exceeding AL | Exceeds AL<br>(Yes/No) | Sample<br>Date | Typical Source  |
|--|------------------|-----|---------------|---------------------------|------------------------|----------------|---|
| Copper-action level at consumer taps (ppm) | 1.3              | 1.3 | 0.068         | 0                         | No                     | 9/7/2018       | Corrosion of household plumbing systems. Erosion of natural deposits. |
| Lead-action level at consumer taps (ppb)   | 0                | 15  | 3.7           | 0                         | No                     | 9/7/2018       | Corrosion of household plumbing systems. Erosion of natural deposits. |

Disinfectants and Disinfection By-Products

(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)

| Disinfectants and Disinfection By- Products | MCLG or<br>MRDLG      | MCL, TT,<br>or MRDL | Highest<br>Level<br>Detected | Range of<br>Levels<br>Detected | Violation<br>(Yes or No) | Sample<br>Date | Typical Source                             |
|---|-----------------------|---------------------|------------------------------|--------------------------------|--------------------------|----------------|--|
| Total Trihalomethanes<br>(TTHM) (ppb)       | No goal for the total | 80                  | 1.0                          | 0 – 1.27                       | No                       | 2020           | By-product of drinking water disinfection. |

Chemical and Radionuclide Constituents

| Contaminants (unit of measure)                  | MCLG or<br>MRDLG | MCL, TT,<br>or MRDL | Detect in<br>Your<br>Water | Range            | Violation<br>(Yes or No) | Sample<br>Date | Typical Source   |
|---|------------------|---------------------|----------------------------|------------------|--------------------------|----------------|--|
| Nitrate (ppm)                                   | 10               | 10                  | 0.14                       | 0-0.14           | No                       | 2020           | Runoff from fertilizer use. Erosion of natural deposits. |
| Sodium (ppm)                                    | NA               | NA                  |                            |                  |                          |                | Erosion of natural deposits.                             |
| Gross alpha excluding radon and uranium (pCi/L) | 0                | 15                  | 0.892                      | 0.669 –<br>0.892 | No                       | 2020           | Erosion of natural deposits.                             |

# Compliance with Other Drinking Water Regulations

CITY OF DENMARK (0510002) did not incur any health-based violations for the calendar year. We met all required compliance monitoring.

Tables for Unit Descriptions and Important Drinking Water Definitions

| Term | Definition   |  |  |  |  |
|------|--|--|--|--|--|
| ppm  | ppm; parts per million; or milligrams per liter (mg/L) |  |  |  |  |
| ppb  | ppb; parts per billion; or micrograms per liter (ug/L) |  |  |  |  |
| NA   | NA; not applicable                                     |  |  |  |  |
| ND   | ND; not detected                                       |  |  |  |  |
| NR   | NR; Monitoring not required but recommended            |  |  |  |  |

| Important D                    | rinking Water Definitions   |
|--------------------------------|---|
| Term                           | Definition  |
| MCLG                           | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.  |
| MCL                            | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.   |
| TT                             | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.  |
| AL                             | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.   |
| Variances<br>and<br>Exemptions | Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.   |
| MRDLG                          | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL                           | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.                              |
| MNR                            | MNR: Monitored Not Regulated  |
| MPL                            | MPL: State Assigned Maximum Permissible Level   |

#### For more information please contact:

SC0510002 TOWN OF DENMARK (0510002)

GERALD WRIGHT, MAYOR 64 CITY HALL STREET DENMARK SC 29042 Phone: 803-793-3734 Page 3 of 4