

Colprovia Asphalt Company  
 Cold Mix Asphalt Plant No. 01  
 Columbia, South Carolina  
 Result - Test of May 16, 2002  
 Permit No. 9900-0025  
 ID No. 01

**Particulate (Method 5)**

Run #	Production tons/hr	Emissions		Allowable lb/hr
		gr/dscf	lb/hr	
1	91.0	0.0646	7.567	14.0
2	90.3	0.0680	8.210	14.0
Average	90.6	0.0663	7.889	14.0

The rated capacity is 130 lbs/hr.

**Visibles (Method 9)**

Run #	1	2	3
No. of Min	0	18	0
Avg. Rolling Opacity	0	6	0
Max/Min	0	0	0

**Operational Notes:**

1. Two runs conducted due to limited production at the plant.
2. Aggregate moisture content was 2.3% during the test.
3. Visibles were read during the test by SC DHEC personnel.
4. The water pressure to the scrubber was approximately 30 psi during the test.
5. The dryer was fired with natural gas during the test.
6. The plant was producing Type 2 surface mix.

**Status as Tested:**

SC BAQ Permit 9900-0025, Section II, Special Conditions Id. 1, (Particulate).....Compliance  
 SC BAQ Permit 9900-0025, Section II, Special Conditions Id. 1, (Visibles).....Compliance

cc: Jake Frick  
 Annie Richardson  
 Lynda Fletcher  
 Carol Boney  
 Bob Hudson, Central Midlands District  
 Main File

Report Received: June 5, 2002  
 Report Completed: June 21, 2002  
 Report Reviewer: Teresie R. Walker  
 Est. Retest Date: May 2004