

TEST PLAN

Storage Box Number: _____
(YYYY MM ##)

Facility: JCI

Source: Various Sources

Permit #: 1040-0129

Id#: N/A

Type of Testing: NO_x, CO, PM, etc

Location: Florence, SC

Plan Submittal Date: December 15, 2014



Catherine B. Templeton, Director

Promoting and protecting the health of the public and the environment

January 12, 2015

Ms. Lizzette Danner
Johnson Controls Battery Group, Inc.
1800 Paper Mill Road
Florence, SC 29501

RE: Furnaces 1 - 3, Refining Ventilation, Refining Combustion, and Refining Process Test Plan Dated December 2014

Dear Ms. Danner:

The referenced site-specific test plan is approved by the Department provided all applicable testing and monitoring requirements specified in MACT Subpart X are followed. Any deviations from the plan, without prior approval from the Department, may be cause for rejecting the test results.

Since various operating scenarios identifying Furnace NO_x and CO variability were not provided, the Department may not accept those emission rates for use as emission factors for substitution during periods of CEMS downtime, malfunction, or calibration.

Regarding Section 3.2 of the plan, pressure differentials of any baghouses with HEPA filters installed must be summarized from the differential pressure monitoring system at least every 15 minutes during the tests. If the differential pressure monitoring system is down during the tests, manual readings must be recorded at least every hour during the tests. These readings must be included in the final test report.

Regardless of the operating rates stated in the approved plan, the Department expects facilities to operate at rated capacity during stack tests. Facilities that conduct tests at less than rated capacity may have reduced operating and/or emission limits imposed. The level of restriction will be determined from the margin of compliance, operating rate, and other appropriate parameters.

Your request to submit the test report 45 days after completion of the testing is approved.

If I can be of further assistance in this matter, please call me at (803) 898-3897 or e-mail me at fricklj@dhec.sc.gov.

Sincerely,

L. Jake Frick
Compliance Management Division
Bureau of Air Quality

ec: Michael Shroup, BAQ
Derek Brewster, TRC

cc: Compliance File: 1040-0129

Fw: Johnson Controls Test Plan for Furnace 1, 2, & 3 the Refining Process and Combustion stacks and the refining ventilation

Frick, Jake

Mon 1/12/2015 12:29 PM

Sent Items

To:lizzette.danner@jci.com <lizzette.danner@jci.com>;

Cc:dbrewster@trcsolutions.com <dbrewster@trcsolutions.com>;

 1 attachment

JCI Plan Approval.doc;

See attached copy of the approval letter.

Jake Frick
SC Dept. of Health & Environmental Control
Bureau of Air Quality
803.898.3897

From: Frick, Jake

Sent: Tuesday, January 6, 2015 2:23 PM

To: lizzette.danner@jci.com

Cc: dbrewster@trcsolutions.com

Subject: Re: Johnson Controls Test Plan for Furnace 1, 2, & 3 the Refining Process and Combustion stacks and the refining ventilation

Section 1.0 of the plan indicates that the NOx and CO tests on the furnaces will be conducted to develop emission factors. The Department currently requires NOx and CO from the furnaces be determined from the installed CEMS. The Department would have to approve any data substitution procedures using emission factors in lieu of CEMS. If emission factor substitution is approved, the plan would need to be modified to identify target operating scenarios during the emission factor development tests (e.g. furnace loads, etc.) and operating parameters (furnace temperatures, etc.) as current data indicates there a number of variables that may affect NOx and CO emissions. In addition, NOx and CO emission rates (lb/hr basis) from the CEMS will need to be recorded during the tests and those results included in the final test report. If you wish to pursue this further please let me know as soon as possible, otherwise I will approve the plan with the exception of testing for emission factor development.

Since the Furnace scrubbers are not really controlling any of the pollutants in which tests are being conducted at this time and the baghouses are equipped with bag leak detection devices, the recording frequencies in Section 3.2 of the plan is okay.

Thanks

Jake Frick
SC Dept. of Health & Environmental Control
Bureau of Air Quality
803.898.3897

From: Brewster, Derek <DBrewster@trcsolutions.com>

Sent: Monday, December 15, 2014 2:14 PM

To: Shroup, Michael; Frick, Jake

Subject: Johnson Controls Test Plan for Furnace 1, 2, & 3 the Refining Process and Combustion stacks and the refining ventilation

Mr Shroup,

Attached is the test plan for Johnson Control testing for January 2015. Testing includes sampling on the Furnaces Nos. 1, 2 & 3, the Refining Process and Combustion Stacks and the refining ventilation process. Please let me know if you have any questions.

Sincerely,

Derek Brewster
Project Manager

TRC Environmental Corporation



5540 Centerview Drive, Suite 100, Raleigh, NC 27606

T: 919.256.6233 | F: 919.838.9661 | C: 919.618.3198

Email: dbrewster@trcsolutions.com

[LinkedIn](#) | [Twitter](#) | [Blog](#) | [Flickr](#) | www.trcsolutions.com

RE: Johnson Controls Test Plan for Furnace 1, 2, & 3 the Refining Process and Combustion stacks and the refining ventilation

Lizzette Danner <lizzette.danner@jci.com>

Mon 1/12/2015 11:51 AM

Inbox

To:Frick, Jake <frickl@dhc.sc.gov>;

Cc:dbrewster@trcsolutions.com <dbrewster@trcsolutions.com>;

Per our conversation...below is a link to the regulatory citation which is 63.548(g). Please let me know if you need anything else.

http://www.ecfr.gov/cgi-bin/text-idx?SID=a934238754f3e69728f56c8bfde8c863&node=sp40.10.63.x&rgn=div6#se40.10.63_1548

Thanks,
Liz

Lizzette Danner

Environmental Compliance Manager; Florence Recycling Center

Johnson Controls Power Solutions

Tel: +1-843-673-5525

Mobile: +1-843-245-1720

Email: lizzette.danner@jci.com

Internet: www.johnsoncontrols.com

Johnson Controls, Inc.

1800 Paper Mill Road

Florence, SC 29506 USA

From: Frick, Jake [mailto:frickl@dhc.sc.gov]

Sent: Tuesday, January 06, 2015 2:24 PM

To: Lizzette Danner

Cc: dbrewster@trcsolutions.com

Subject: Re: Johnson Controls Test Plan for Furnace 1, 2, & 3 the Refining Process and Combustion stacks and the refining ventilation

Section 1.0 of the plan indicates that the NOx and CO tests on the furnaces will be conducted to develop emission factors. The Department currently requires NOx and CO from the furnaces be determined from the installed CEMS. The Department would have to approve any data substitution procedures using emission factors in lieu of CEMS. If emission factor substitution is approved, the plan would need to be modified to identify target operating scenarios during the emission factor development tests (e.g. furnace

loads, etc.) and operating parameters (furnace temperatures, etc.) as current data indicates there a number of variables that may affect NOx and CO emissions. In addition, NOx and CO emission rates (lb/hr basis) from the CEMS will need to be recorded during the tests and those results included in the final test report. If you wish to pursue this further please let me know as soon as possible, otherwise I will approve the plan with the exception of testing for emission factor development.

Since the Furnace scrubbers are not really controlling any of the pollutants in which tests are being conducted at this time and the baghouses are equipped with bag leak detection devices, the recording frequencies in Section 3.2 of the plan is okay.

Thanks

Jake Frick
SC Dept. of Health & Environmental Control
Bureau of Air Quality
803.898.3897

From: Brewster, Derek <DBrewster@trcsolutions.com>

Sent: Monday, December 15, 2014 2:14 PM

To: Shroup, Michael; Frick, Jake

Subject: Johnson Controls Test Plan for Furnace 1, 2, & 3 the Refining Process and Combustion stacks and the refining ventilation

Mr Shroup,

Attached is the test plan for Johnson Control testing for January 2015. Testing includes sampling on the Furnaces Nos. 1, 2 & 3, the Refining Process and Combustion Stacks and the refining ventilation process. Please let me know if you have any questions.

Sincerely,

Derek Brewster
Project Manager

TRC Environmental Corporation



5540 Centerview Drive, Suite 100, Raleigh, NC 27606

T: 919.256.6233 | F: 919.838.9661 | C: 919.618.3198

Email: dbrewster@trcsolutions.com

[LinkedIn](#) | [Twitter](#) | [Blog](#) | [Flickr](#) | www.trcsolutions.com



Test Protocol

Performance Tests on Furnaces 1, 2, & 3,
Refining Ventilation, Refining Combustion
and Refining Process

at the

Johnson Controls Battery Group, Inc.
Florence Recycling Plant

Florence, South Carolina

Prepared for:

Johnson Controls Battery Group, Inc.
Florence Recycling Plant
1800 Paper Mill Road
Florence, South Carolina 29501

Prepared by:

TRC Environmental Corporation
5540 Centerview Drive, Suite 100
Raleigh, North Carolina 27606

December 2014

TRC Project No. 223508

December 2014

TEST PROTOCOL

**Performance Tests on Furnaces 1, 2 & 3,
Refining Ventilation, Refining Combustion
And Refining Process**

**At the
Johnson Controls Battery Group, Inc.
Florence Recycling Plant**

Florence, South Carolina

Prepared for

Johnson Controls Battery Group, Inc.
Florence Recycling Plant
1800 Paper Mill Road
Florence, South Carolina 29501

Prepared by

TRC Environmental Corporation
5540 Centerview Drive, Suite 100
Raleigh, North Carolina 27606
(919) 828-3150



TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	5
2.0 PROJECT OVERVIEW	7
2.1 SCOPE OF WORK	7
2.2 OPERATING SCHEDULE	8
3.0 FACILITY DESCRIPTION	9
3.1 SITE LOCATION AND SOURCE DESCRIPTION	9
3.2 PLANT PROCESS DATA	10
4.0 TEST METHODS AND PROCEDURES	11
4.1 OVERVIEW	11
4.2 FIELD PROGRAM DESCRIPTION	11
4.3 PRE-SAMPLING ACTIVITIES	12
4.3.1 Equipment Calibration	12
4.3.2 Source Sampling Equipment	13
4.4 ONSITE SAMPLING ACTIVITIES	13
4.4.1 Velocity Measurements	13
4.4.2 Flue Gas Moisture	14
4.4.3 Flue Gas Molecular Weight	14
4.4.4 Particulate Matter and Metals	14
4.4.5 Mercury	15
4.4.6 Continuous Emissions Monitoring for O ₂ , CO ₂ , NO _x , CO and SO ₂	17
5.0 CALCULATIONS	18
5.1 Concentration, grains per dry standard cubic foot	18
5.2 Emission Rate, pounds per hour	18
6.0 QUALITY ASSURANCE	19
6.1 OVERVIEW	19
6.2 FIELD QUALITY CONTROL SUMMARY	19
6.2.1 Calibration Procedures	19
6.3 DATA REDUCTION, VALIDATION, AND REPORTING	20
6.3.1 Field Data Reduction	20
6.3.2 Data Validation	20
6.3.3 Data Reporting	21
6.4 STATIONARY SOURCE AUDIT SAMPLES	21
6.5 EXCEPTIONS	21
7.0 FINAL REPORT SUMMARY	22
7.1 INTRODUCTION	22

7.2	SUMMARY AND DISCUSSION OF RESULTS	22
7.2.1	Summary of Results	22
7.2.2	Discussion of Results	23
7.3	PROCESS DESCRIPTION AND OPERATION.....	23
7.3.1	Process Description.....	23
7.3.2	Process Operations.....	23
7.4	SAMPLING LOCATIONS	23
7.5	SAMPLING PROCEDURES.....	23
7.6	DATA REPORTING.....	23
7.7	APPENDICES	24
7.8	REPORT APPROVAL.....	24
7.9	ELECTRONIC REPORTING TOOL	24

1.0 INTRODUCTION

TRC Environmental Corporation (TRC) of Raleigh, North Carolina has been retained by Johnson Controls Battery Group, Inc. (JCI) to conduct performance tests at the Florence Recycling Plant located at 1800 Paper Mill Road in Florence, South Carolina, SC Permit Number 1040-0129-CA.

Performance testing will be conducted as follows:

Location	Unit ID	Monitoring Parameter(s)
Furnace 1*	07	Particulate matter (PM), Lead (Pb), Mercury (Hg), Sulfur dioxide (SO ₂), Nitrogen Oxides (NO _x) and Carbon monoxide (CO).
Furnace 2*	08	Particulate matter (PM), Lead (Pb), Mercury (Hg), Sulfur dioxide (SO ₂), Nitrogen Oxides (NO _x) and Carbon monoxide (CO).
Furnace 3*	09	Particulate matter (PM), Lead (Pb), Mercury (Hg), Sulfur dioxide (SO ₂), Nitrogen Oxides (NO _x) and Carbon monoxide (CO).
Refining Ventilation	12	Particulate matter (PM), lead (Pb).
Refining Combustion	11A	Sulfur dioxide (SO ₂), Carbon monoxide (CO).
Refining Process	11B	Particulate matter (PM), Lead (Pb), Mercury (Hg), Sulfur dioxide (SO ₂) and Carbon monoxide (CO).

* Testing for NO_x and CO at the furnaces will be conducted to develop emission factors for each individual furnace.

All testing will be conducted while the unit is operating at greater than 90% of maximum normal load under steady state conditions.

Lead testing is being performed as required by 40 CFR 63 Subpart X, Section 63.543(g)(8) and Section II.C. of permit 1040-0129-CA. All other testing described in this protocol is being conducted in accordance with Section II.C. of permit 1040-0129-CA.

Johnson Controls Battery Group, Inc.
Florence Recycling Plant
Florence, South Carolina

FACILITY CONTACT INFORMATION

Ms. Lizzette Danner
Environmental Manager
Johnson Controls Battery Group, Inc. – Florence Recycling Plant
1800 Paper Mill Road
Florence, South Carolina 29501
Telephone: 843-245-1720

TESTING FIRM INFORMATION

Derek Brewster
Project Manager
TRC Environmental Corp.
5540 Centerview Drive, Suite 100
Raleigh, NC 27606
Telephone: (919) 618-3198

CONTRACT LABORATORY INFORMATION

Steve Hunter
Laboratory Manager
First Analytical Laboratories
7517 Precision Drive, Suite 101
Raleigh, NC 27617
Telephone: (919) 942-8607

2.0 PROJECT OVERVIEW

2.1 SCOPE OF WORK

Testing will be conducted for particulate matter (PM) and lead (Pb) at Furnaces 1, 2 & 3, the Refining Ventilation Stack, and the Refining Process stack. Mercury testing will be conducted at Furnaces 1, 2 & 3, and the Refining Process. Sulfur dioxide and carbon monoxide testing will be conducted at Furnaces 1, 2 & 3, Refining Combustion, and Refining Process. Nitrogen oxide testing will be conducted on Furnaces 1, 2 & 3. Although Furnaces 1, 2, & 3 are each equipped with continuous emission monitoring systems for nitrogen oxides and carbon monoxide the testing will be conducted to develop furnace specific emission factors for each pollutant. The test program approach involves conducting a series of three test runs at each location using EPA Reference Methods.

The required measurement parameters and test methods to accomplish these objectives are:

40 CFR Part 60, Appendix A, EPA Methods

- Method 1 and 2 Volumetric Flow Rate Determination
- Method 3 or 3A Oxygen and Carbon Dioxide
- Method 4 Moisture
- Method 5 Particulate matter
- Method 6C Sulfur Dioxide
- Method 7E Nitrogen Oxides
- Method 10 Carbon Monoxide
- Method 29 Lead
- Method 30B Mercury

2.2 OPERATING SCHEDULE

Performance testing for particulate matter, mercury, lead, nitrogen oxides, carbon monoxide and sulfur dioxide will be conducted while the designated unit is operating under maximum representative operating conditions defined as operation at greater than 90% of capacity throughout the test period. Process rates to be recorded as follows:

Source	Unit ID	Process Rate Description	Design Rate ¹
Furnace 1	07	Furnace lead production	4.72 tons/hour
Furnace 2	08	Furnace lead production	4.72 tons/hour
Furnace 3	09	Furnace lead production	4.72 tons/hour
Refining Ventilation ²	12	Total lead production and total casting	14.16 tons/hour (receipts from furnaces) 17.34 tons/hour (lead ingots)
Refining Combustion	11A	Total lead production and total casting	14.16 tons/hour (receipts from furnaces) 17.34 tons/hour (lead ingots)
Refining Process	11B	Total lead production and total casting	14.16 tons/hour (receipts from furnaces) 17.34 tons/hour (lead ingots)

¹ The process rate will be defined as the hourly average of the batch process. The charging start time and mass will be logged as well as the final tap time and mass.

² The refining ventilation will consist of sampling one of four representative roof vents with temporary stack extension and applying the emission rates to all four emission points.

3.0 FACILITY DESCRIPTION

Johnson Controls Battery Group, Inc. – Florence Recycling Plant operates several processes in which discarded lead-acid batteries are recycled.

3.1 SITE LOCATION AND SOURCE DESCRIPTION

Each emission unit in this test program is equipped with an individual, dedicated exhaust stack. The Smelting Furnaces No. 1, No. 2 and No. 3 (Unit IDs 07, 08 & 09) are identical rotary smelting furnaces rated at 19.15 MMBtu/hr each and fired on natural gas. Each individual furnace is controlled by a 6.13 MMBtu/hr afterburner followed by a baghouse with HEPA filtration and a wet scrubber. The Refining Kettles and Casting consist of nine (9) refining kettles each rated at 9.58 MMBtu/hr and the casting burner rated at 1.15 MMBtu/hr. The process gases are collected in the Refining Process (Unit ID 11A) and combustion-related emissions from the kettles are collected in Refining Combustion (Unit ID 11B). The process emissions are controlled by a baghouse with HEPA filtration. The Refining Ventilation emissions (Unit ID 12) consist of the negative pressure system for the refining and casting fugitives. A temporary stack extension will be installed to conduct the testing on the Refining Ventilation location. All sampling will be conducted at one representative location and applied to the four (4) refining ventilation emission point that are part of the process.

Complete descriptions of each location will be documented in the final test report. The test report will include all EPA Method 1 parameters including stack diameter and upstream / downstream measurements as well as cyclonic flow determinations.

3.2 PLANT PROCESS DATA

JCI personnel will be responsible for the documentation of facility operating conditions during the test program. Plant operating data collected by JCI plant personnel will be included in the final report. The process data may include and is not limited to:

- Process operating rates – as described in Section 2.2
- Baghouses and HEPAs pressure differential – readings collected on a per shift basis
- Furnaces afterburners temperatures – Continuous monitoring
- Furnaces scrubbers pH – readings collected on a per shift basis
- Furnaces scrubbers liquid flow – readings collected on a per shift basis
- Furnaces scrubbers liquid to gas ratio – readings collected on a per shift basis
- Total enclosure pressure differentials (smelter enclosure) – 15 minute averages that will include at least one reading per minute

4.0 TEST METHODS AND PROCEDURES

4.1 OVERVIEW

This section describes the procedures that the testing contractor will follow during the field sampling program. Throughout the program, the testing contractor will follow EPA Reference Methods 40 CFR Part 60 Appendix A and Appendix B sampling protocols. The testing contractor project manager, the JCI project coordinator and South Carolina Department of Health and Environmental Control (SC DHEC) will approve deviations from the specified test methods. Modifications will be documented in the final report.

The remainder of this section is divided into the following subsections: Field Program Description, Pre-sampling Activities, and Onsite Sampling Activities.

4.2 FIELD PROGRAM DESCRIPTION

The following test methods will be used:

The test methods to be utilized in accordance with 40 CFR Part 60 will be as follows:

- EPA Method 1 Sample Velocity Traverse for Stationary Sources
- EPA Method 2 Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot tube)
- EPA Method 3 Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources
- EPA Method 3A Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)
- EPA Method 4 Determination of Moisture Content in Stack Gases
- EPA Method 5 Determination of Filterable Particulate from Stationary Sources

- EPA Method 6C Determination of Sulfur Dioxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)
- EPA Method 7E Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure)
- EPA Method 10 Determination of Carbon Monoxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)
- EPA Method 29 Determination of Metals Emissions from Stationary Sources
- EPA Method 30B Determination of Total Vapor-Phase Mercury using Carbon Sorbent Traps.

4.3 PRE-SAMPLING ACTIVITIES

Pre-sampling activities include equipment calibration and other miscellaneous tasks. Each of these activities are described or referenced in the following subsections. Other pre-sampling activities include team meetings, equipment packing, and finalization of all details leading up to the coordinated initiation of the sampling program.

4.3.1 Equipment Calibration

The testing contractor will follow an orderly program of positive actions to prevent the failure of equipment or instruments during use. Preventative maintenance and careful calibration help to ensure accurate measurements from field and laboratory instruments.

Once the equipment has gone through the cleaning and repair process, it is then calibrated. All equipment that is scheduled for field use is cleaned and checked prior to calibration. Once the equipment has been calibrated, it is packed and stored to ensure the integrity of the equipment. An adequate supply of spare parts is taken in the field to minimize downtime from equipment failure.

Inspection and calibration of the equipment is a crucial step in ensuring the successful completion of the field effort. All equipment is inspected for proper operation and durability prior to calibration. Calibration of the following equipment is conducted in accordance with the

procedures outlined in EPA documents entitled "*Quality Assurance Handbook for Air Pollution Measurement Systems; Volume III - Stationary Source Specific Methods*" (EPA-600/4-77-027b) and 40 CFR Part 60 Appendix A. All calibrations will be performed prior to test program.

4.3.2 Source Sampling Equipment

Each sampling console dry gas meter is calibrated with critical orifices or by comparison to a reference gas meter. The resulting gas meter coefficient (γ or gamma) and the orifice pressure differential (ΔH) are clearly labeled on the meterbox as applicable. The pitot tubes are checked for conformance to the geometric specification in EPA Method 2 and are assigned a coefficient of 0.84. Thermocouples are initially calibrated by comparison with an ASTM-3F mercury-in-glass thermometer at three points. Each thermocouple will agree within 1.5 percent of the reference thermometer, expressed in Kelvin, throughout the entire calibration range. Digital temperature indicators are checked by comparing the indicator reading with a series of input signals from a digital readout calibrator.

4.4 ONSITE SAMPLING ACTIVITIES

4.4.1 Velocity Measurements

Velocity traverses will be conducted at each stack with an S-type pitot assembly in accordance with EPA Reference Methods 1 and 2. An S-type pitot tube with an attached inclined manometer will be used to measure the exhaust velocities at the sampling location. An attached Type-K thermocouple with remote digital display will be used to determine the flue gas temperature. During the test program, velocity measurements will be conducted during each test run while operating the isokinetic sampling train(s). The required number of velocity measurement points for each sampling location will be determined following EPA Method 1.

Cyclonic flow checks will be conducted in accordance with Section 2.4 of EPA Method 1. This procedure is referred to as the nulling technique. An S-type pitot tube connected to an inclined manometer will be used in this method. The pitot tube will be positioned at each traverse point so that the face openings of the pitot tube are perpendicular to the stack cross-sectional plane. This position is called the "0° reference". The velocity pressure (ΔP) measurement is noted. If the ΔP reading is zero, the cyclonic angle is recorded as 0°. If the ΔP reading is not zero, the

pitot tube is rotated clockwise or counter clockwise until the ΔP reading becomes zero. This angle is then measured with a leveled protractor and reported to the nearest degree. After this null technique is applied at each traverse point, the average of the cyclonic angles is calculated. If this average is less than 20° , the flow condition is acceptable to test.

4.4.2 Flue Gas Moisture

Moisture will be determined for each test run according to EPA Reference Method 4, "*Determination of Moisture Content in Stack Gases*". The principle of this method is to remove the moisture from the sample stream and determine moisture either volumetrically or gravimetrically. Method 4 will be used in conjunction with the metals and sampling train. A stand-alone moisture train will consist of four impingers. The first two impingers will contain water, the third will remain empty and the fourth will contain silica gel. Stand-alone Moisture samples will be collected from a single point for 30 minutes. Each moisture sample collected will be applied to two volumetric flow measurements.

4.4.3 Flue Gas Molecular Weight

Molecular weight will be determined for each test run according to EPA Reference Method 3 or 3A, "*Determination of Dry Molecular Weight*". Concurrent with the isokinetic sampling, an integrated tedlar bag sample will be collected. The bag will be analyzed with an Orsat analyzer for the percent oxygen and carbon dioxide in the gas stream. This data will be used for determining the dry molecular weight of the stack gas. Instrumental reference method sampling for oxygen and carbon dioxide may be used for determination of flue gas molecular weight. Details of the instrumental procedure are found in Section 4.4.5.

4.4.4 Particulate Matter and Metals

Sample Collection. Samples are withdrawn isokinetically from the stack using an EPA Method 5 and 29 sampling train, where applicable. The sampling train will consist of a glass nozzle, a heated glass probe with a Type S Pitot tube attached, a heated filter, four chilled impingers, and a metering console. The filter will be a tared quartz fiber filter maintained at a temperature of $248^\circ\text{F} \pm 25^\circ\text{F}$. The first two impingers will each contains 100 ml of 5% nitric acid (HNO_3) / 10% hydrogen peroxide (H_2O_2) reagent, the third will remain empty and the fifth will contain

pre-weighed silica gel. Each point will be sampled for an equal amount of time, resulting in net run times of 240 minutes and a minimum sample volume of 70 dry standard cubic feet. The actual number of sampling points will be determined after evaluating the Method 1 criteria.

Sample Recovery. The sample train will be transported to the on-site trailer for clean-up. The filter is removed from the filter holder and placed in a petri dish. The impingers are weighed prior to sample train recovery. The silica gel is returned to the original container. The volume of water vapor condensed in the impingers and the volume of water vapor collected in the silica gel are summed and entered into moisture content calculations. All front-half components of the sampling train including the nozzle, probe, and filter holder are rinsed with acetone into a reagent jar followed by 100 ml nitric acid rinse into a separate reagent jar. The first through third impingers are emptied into a 1000 ml reagent jar. The back-half of the filter holder through the third impinger are then rinsed with 100 ml 0.1N HNO₃ into the same jar. Three (3) unused filters from the same lot and treated in the same manner as above will be designated as a blank. Reagent blanks will be collected as described in EPA Method 29. A spike is added to one run during analysis to obtain the recovery efficiency.

Sample Analysis. EPA Method 5 analytical procedures are used to analyze the filter and acetone rinse for total filterable particulate matter following the procedures outlined in section 8.3.1.1 and 8.3.2 of Method 29. EPA Method 29 analytical procedures are used to analyze the sample train for antimony lead (Pb). Method 29 front and back half fractions are analyzed separately. Duplicate metals analysis is performed for approximately 10% of the samples for metals except for mercury. All mercury samples are analyzed in duplicate.

4.4.5 Mercury

Sample Collection. Samples are withdrawn at a constant rate from the source using an EPA Method 30B sampling system. Each of the paired legs, designated A and B, of the sampling train consist of a 10mm O.D. charcoal tube, a heated probe, a moisture knock out, and a metering console. At the conclusion of each sampling run, the charcoal tube from each leg is leak checked, removed from the heated probe, labeled, and sealed. The analyte measured is total vapor-phase Hg in the flue gas, which represents the sum of elemental Hg (Hg⁰) and oxidized forms of Hg, in mass concentration units of micrograms per dry standard cubic meter (µg/dscm). The sorbent traps are recovered from the sampling system and delivered to the analytical

laboratory. The spiked traps will be calculated based on a stack concentration of 0.5 µg/dscm and the target sample volume will be roughly 300 L. The actual run time will be determined based on equipment configuration and actual sample rate that can be achieved. The target run time will be 180 - 240 minutes. All three sample runs will be the same duration and method required sample volume criteria will be met.

EPA Method 30B analytical procedures are used to analyze the charcoal tubes for mercury. All paired tubes used in the calculations need to be within the allowable relative difference of 10%, and the average spike recovery within the allowable 85% to 115% range. Breakthrough parameters include the second fraction of the individual tube being less than 10% of the total concentration.

Sample Analysis. Analysis of each paired sorbent tube will be conducted using an Ohio Lumex model RA-915 fitted with the RP-M324 thermal attachment to analyze each fraction of the charcoal tubes. The Ohio Lumex analyzer will be calibrated from 10 ng to 1,000 ng using NIST traceable standards. A 500 ng continuing calibration verification (CCV) will be prepared in accordance with the method, at a minimum every tenth sample. The charcoal tube is processed and sorbent is transferred onto a quartz ladle. The ladle is inserted into the analyzer thermo catalytic conversion chamber (RP-M324) heated to ~ 700°C wherein mercury is converted from a bound state to the atomic state by thermal decomposition in a two-section furnace. Mercury measurements take place in the heated cell zone of converter directly coupled to spectrometer. High temperature (~ 700°C) and short residence time prevents mercury atoms from recombining with any “active” species generated due to high temperature decomposition of sample matrix. An external pump is used to draw ambient air and purify it for combustion.

The RA-915 is also equipped with custom integration software that charts and records each individual sample. This software integrates each sample peak providing the user with an area count equivalent that is used to generate nanograms (ng) mercury per sample fraction.

The charcoal sorbent tube consists of two fractions separated by a layer of glass wool. The first section is the sample fraction. The second fraction is analyzed for breakthrough. The two fractions from each tube are summed and the total mercury analyzed is used to determine concentration. In the event that the second fraction was analyzed to be less than the minimum detection limit (MDL) of the instrument, the MDL was used as the Hg catch for that fraction.

4.4.6 Continuous Emissions Monitoring for O₂, CO₂, NO_x, CO and SO₂

Instrumental Reference Method testing will be conducted for Nitrogen Oxides (EPA Method 7E), Carbon Monoxide (EPA Method 10) and Sulfur dioxide (EPA Method 6C). Oxygen (EPA Method 3A) and carbon dioxide (EPA Method 3A) will be measured to calculate stack gas molecular weight for flow rate determination. The instrumental test data will be collected concurrent with the isokinetic sampling and volumetric flow rates will determined during the isokinetic sampling will be applied.

The reference method CEMS sampling train will start with a stainless-steel sampling probe. The sample stream will be then drawn through a glass fiber filter, heated (248°F ± 25°F) Teflon sample line, and a sample conditioner to remove the moisture and particulate from the gas stream. The sample will then be drawn through Teflon tubing by a leak-free Teflon pump to a stainless-steel sample manifold with an atmospheric by-pass rotameter. The O₂, CO₂, NO_x, CO and SO₂ analyzers will withdraw samples from this manifold.

CEMS data will be recorded as averages by a digital data logger designed to receive and log instrument signals. The results will be expressed in ppmvd for NO_x, CO and SO₂, and in percent for O₂ and CO₂.

5.0 CALCULATIONS

5.1 Concentration, grains per dry standard cubic foot

$$C \text{ (gr/dscf)} = 15.4324 \times \frac{\text{g}}{\text{Vmstd}}$$

Where:

C	=	Concentration, gr/dscf
15.4324	=	conversion gr/mg, (7,000 gr/lb) / (453.592 mg/lb)
Vmstd	=	Volume metered @ standard conditions

5.2 Emission Rate, pounds per hour

Concentrations, parts per million (ppm) and milligrams per dry standard cubic meter (mg/dscm) will be corrected to 7% oxygen using the following equation:

$$R_t \text{ (lb/hr)} = \frac{60}{453.592} \times \frac{\text{g}}{\text{Vmstd}} \times Q_{sd}$$

OR

$$R_t \text{ (lb/hr)} = \frac{60 \times \text{fwt} \times Q_{sd}}{385.3 \times 10^6}$$

Where:

R _t	=	Emission Rate, lb/hr
Q _{sd}	=	Volumetric Flow Rate, DSCFM
Fwt	=	Formula Weight of Pollutant, lb/lb-mole

6.0 QUALITY ASSURANCE

6.1 OVERVIEW

The testing contractor management will be fully committed to an effective Quality Assurance/Quality Control Program whose objective is the delivery of a quality product. That product is data resulting from field measurements, sampling and analysis activities, engineering assessments, and the analysis of gathered data for planning purposes. The Quality Assurance Program works to provide complete, precise, accurate, representative data in a timely manner for each project, considering both the project's needs and budget constraints.

This section highlights the specific QA/QC procedures to be followed on this Test Program.

6.2 FIELD QUALITY CONTROL SUMMARY

6.2.1 Calibration Procedures

Calibration of the field sampling equipment will be performed prior to the field sampling effort. Copies of the calibration sheets will be submitted to the field team leader to take onsite and for the project file. Calibrations will be performed as described in the EPA publications "*Quality Assurance Handbook for Air Pollution Measurement Systems; Volume III - Stationary Source Specific Methods*" (EPA-600/4-77-027b) and EPA 40 CFR Part 60 Appendix A.

The following EPA approved alternative will be used for thermocouple calibration:

Post-test thermocouple calibration will be performed in accordance with EPA ALT-011 using a single point calibration against an ASTM mercury-in-glass thermometer in addition to a continuity check of the thermocouple. The continuity check involves verifying that the thermocouple read-out trends in the appropriate direction when exposed to a temperature change. A complete copy of EPA ALT-011 is available from EPA from the EMC website at <http://www.epa.gov/ttn/emc/>.

6.3 DATA REDUCTION, VALIDATION, AND REPORTING

Specific QC measures will be used to ensure the generation of reliable data from sampling and analysis activities. Proper collection and organization of accurate information followed by clear and concise reporting of the data is a primary goal in all projects.

6.3.1 Field Data Reduction

Standardized forms will be used to record field sampling data. The data collected will be reviewed in the field by the Field Team Leader and at least one other field crew member. Errors or discrepancies will be noted in a field log.

6.3.2 Data Validation

The testing contractor supervisory and QC personnel will use validation methods and criteria appropriate to the type of data and the purpose of the measurement. Records of all data will be maintained, including that judged to be an "outlying" or spurious value. The persons validating the data will have sufficient knowledge of the technical work to identify questionable values.

Field sampling data will be validated by the Field Team Leader and/or the Field QC Coordinator based on their review of the adherence to an approved sampling protocol and written sample collection procedure.

The following criteria will be used to evaluate the field sampling data:

- Use of approved test procedures;
- Proper operation of the process being tested;
- Use of properly operating and calibrated equipment;
- Leak checks conducted before and after tests;
- Use of reagents conforming to QC specified criteria; and
- Maintain proper chain-of-custody.

6.3.3 Data Reporting

All data will be reported in standard units depending on the measurement and the ultimate use of the data. The bulk of the data will be processed following delivery of the laboratory results.

6.4 STATIONARY SOURCE AUDIT SAMPLES

Stationary source audit samples will be ordered for this test program. The order will include an EPA Method 29 audit for metals on filter paper and in impinger solutions. The analysis will be for Lead. An additional audit will be ordered for mercury on filter paper and in impinger solution. All audit samples will be analyzed with the field samples.

6.5 EXCEPTIONS

Any deviations from this test plan must be approved by the JCI project coordinator and SC DHEC. Deviations will be documented in the final report.

7.0 FINAL REPORT SUMMARY

This section will serve as an outline of the Final Reports for submittal to JCI. This test program is projected to occur the week of December 8, 2014. Two (2) test reports will be submitted summarizing the results of the test program. The performance test report will be submitted within 45 days of completion of the test program. The report will follow the same basic outline as described in the following sections.

7.1 INTRODUCTION

The introduction will include the following items:

- The overall goals of the test;
- The specific goals of the test;
- Names and locations of all businesses, contractors, and agencies involved in the tests;
- Dates and duration of the test period;
- A brief outline of the remainder of the report.

7.2 SUMMARY AND DISCUSSION OF RESULTS

This section will be a two-part discussion summarizing the results and conclusions drawn from the data.

7.2.1 Summary of Results

This section will provide an overview of the entire stack gas sampling effort. Emission rates and concentrations will be expressed in the units as noted in Section 6.3.

Process upsets and deviations from the Test Plan will be fully described. Events, whether field or laboratory, pertinent to this project that may have an impact on the quality of the data will be fully documented in this section.

7.2.2 Discussion of Results

In this section, the testing contractor will correlate the emissions data with pertinent process data to further explain the results. Explanations or justifications for data discrepancies will be given. Areas where the data may appear technically weak will be pointed out.

7.3 PROCESS DESCRIPTION AND OPERATION

This section of the report will be in two parts, the process description subsection and the process operation subsection.

7.3.1 Process Description

A complete step-wise description of the entire process will be documented in this subsection. Design capacities and all pertinent process parameters will be listed.

7.3.2 Process Operations

Actual process data relevant to the emissions testing will be provided by the facility for inclusion in an appendix.

7.4 SAMPLING LOCATIONS

This will be similar to Section 3.0 of this Test Plan. Any deviations will be addressed.

7.5 SAMPLING PROCEDURES

This section will describe the methods used and any deviations from the Test Plan. This section will include a full discussion of any problems encountered during sampling.

7.6 DATA REPORTING

The data generated from this test program will be organized into tables depicting the pollutant concentrations from the sampling locations. All data undergoes extensive QA/QC procedures

validating the results. All data will be reported in standard units depending on the measurement and the ultimate use of the data.

7.7 APPENDICES

The following appendices will be included in the Final Report:

- A. Summary of Results and Example Calculations
- B. Field Sampling Data Sheets
- C. Laboratory Analytical Data
- D. Equipment Calibration Sheets
- E. Process Data
- F. Qualified Individual Certification

7.8 REPORT APPROVAL

Senior staff members and QA personnel will review the final report for accuracy and completeness prior to submittal.

7.9 ELECTRONIC REPORTING TOOL

The data collected to meet the 40 CFR 63 Subpart X requirements will be entered in the EPA Webfire database using the EPA Electronic Reporting Tool. This data will be populated within 60 days of the test program completion.

Johnson Controls Battery Group, Inc.
Florence Recycling Plant
Florence, South Carolina

Attachment A

Example Chain of Custody

SAMPLE LOG and CHAIN OF CUSTODY RECORD									
Client:	TRC Environmental Corporation	TRC Project Manager:	Derek Brewster	Page # 1 of 3	First Analytical Laboratory, Inc.				
Location:	Raleigh, NC	Telephone No.	(919) 256-6233		(919) 942-8607				
Project Name:	Johnson Controls Florence, SC	TRC Project No.	210315						
		Carrier or Delivery:	Delivered by TRC						
		Date Delivered to Lab:							
		Results Due Date:	Standard TAT						
Sample I.D. No. and Description	Method	Run #	Fraction :	Sample Date :	Sample Type :	Type of Container :	Analysis Requested		
	M29	M29-1	Filter		Filter	Petri	Pb & Hg by M29		
	M29	M29-1	FH HNO ₃ Rinse		HNO ₃	250 ml glass	Pb & Hg by M29		
	M29	M29-1	HNO ₃ /H ₂ O ₂		HNO ₃ /H ₂ O ₂	950 ml glass	Pb & Hg by M29		
	M29	M29-1	Impinger 4		HNO ₃	250 ml glass	Pb & Hg by M29		
	M29	M29-1	KMnO ₄		KMnO ₄	500 ml Amber	Hg by M29		
	M29	M29-1	HCl		HCl in H ₂ O	500 ml glass	Hg by M29		
	M29	M29-2	Filter		Filter	Petri	Pb & Hg by M29		
	M29	M29-2	FH HNO ₃ Rinse		HNO ₃	250 ml glass	Pb & Hg by M29		
	M29	M29-2	HNO ₃ /H ₂ O ₂		HNO ₃ /H ₂ O ₂	950 ml glass	Pb & Hg by M29		
	M29	M29-2	Impinger 4		HNO ₃	250 ml glass	Pb & Hg by M29		
	M29	M29-2	KMnO ₄		KMnO ₄	500 ml Amber	Hg by M29		
	M29	M29-2	HCl		HCl in H ₂ O	500 ml glass	Hg by M29		
	M29	M29-3	Filter		Filter	Petri	Pb & Hg by M29		
	M29	M29-3	FH HNO ₃ Rinse		HNO ₃	250 ml glass	Pb & Hg by M29		
	M29	M29-3	HNO ₃ /H ₂ O ₂		HNO ₃ /H ₂ O ₂	950 ml glass	Pb & Hg by M29		
	M29	M29-3	Impinger 4		HNO ₃	250 ml glass	Pb & Hg by M29		
	M29	M29-3	KMnO ₄		KMnO ₄	500 ml Amber	Hg by M29		
	M29	M29-3	HCl		HCl in H ₂ O	500 ml glass	Hg by M29		
Released by TRC	Signature	Date	Accepted by Laboratory	Signature and Date					